



# Low-cost Sensor Training Global Best Practices and Toolkits: The Afri-SET Experience

**Presented by:**

**Dr Allison F. Hughes**

**&**

**Mathias A. Borketey**

**Afri-SET Project, University of Ghana**



**Various sources of Air pollution in Africa (Ghana)**



# Afri-SET : The Air Quality Sensor Evaluation and Training Centre for West Africa

## Objectives 1

1. To establish a low-cost air sensor evaluation and training hub in Ghana-West Africa



i. Develop Standard Operating Procedures (SOPs) (vetted by AQ-SPEC, AirParif & NILU)



ii. Evaluate 10 sensor types in each year

iii. Build a website to host reports, calibration protocols and other materials in both English and French. ([www.afri-set.org](http://www.afri-set.org))



Norsk institutt for luftforskning  
Norwegian Institute for Air Research

# Afri-SET facility

November 2022



February 2025



February 2026



# Objectives 2

2. To facilitate capacity building of students and air quality practitioners in Africa



Workshop at Carnegie Mellon University (Kigali, Rwanda) March 2023



5-day Workshop at University of Ghana, (Accra, Ghana) January 2024




5-day Workshop at University of Ghana, (Accra, Ghana) January 2025

- All seminar/workshop materials are available for free on our website and YouTube channel

# Objectives 3

## 3. To promote long-term sustainability and replication of the center


- i. Explore funding, partnership, and other opportunities to replicate the center in other regions of Africa
- ii. Monetizing training services (in-person and virtual)
- iii. Establishing consulting service for LCS (e.g. analyzing other users' data, deployments, etc.)



Afri-SET's Researchers visit to NILU, AQSPEC & Airparif

# Sensor Evaluation and Calibration at Afri-SET

# Reference Monitors



Teledyne T640

Ecotech Serinus 40 NOx analyser



2B Tech Ozone monitor

# 40+ LCS installed at Afri-SET Facility



Airbeam3



atmotube



Airly



Purpleair



Modulair



Airgradient



Kunak



Clarity-NS



Praxis



Atmos



IQAir



AirQo



SensorAfrica



Air Quality EGG



TSI-Bluesky

# Standard Operating Procedure(SOP)

- ❑ Number of sensors (at least 3 identical sensor units)
- ❑ Sensor Pre-deployment (48hr) in lab before field installation
- ❑ Evaluation period - 6 weeks in dry season and 6 weeks in wet season
- ❑ Data analysis and evaluation report




# Air Sensor Installation Considerations

1. Out-of-the-Box Components
2. Sensor set-up procedure
3. Sensor Registration & Data Integration
4. Pre-deployment checks
5. Sensor deployments
6. Post deployment checks

# Various Sensors in Air sensors Units


- Particulate matter (PM) sensor = Plantower (PMS5003T)/Alphasense OPC
- TVOCs/NO<sub>x</sub> sensor = Sensirion (metal oxide sensors)/Alphasense
- CO<sub>2</sub> sensor = SenseAir S8 Non-Dispersive Infrared Radiation (NDIR) CO<sub>2</sub> sensor
- Temperature/Relative Humidity = ENS210 sensor integrated in the PMS5003T



PMS5003T



Alphasense OPC



Sensirion  
(SGP41)




SenseAir S8 NDIR CO<sub>2</sub>


# 1. Hardware Parts List: Out-of-the-Box Components



Open Air Sensor



Sensor base



### Sensor Accessories

- A. 4m USB C to USB A cable
- B. Sensor antenna
- C. 3-pin plug

## 2. Pre-Deployment checks

This is usually done in the laboratory 24 hrs to 48 hrs before deployment

- a) Ensure sensors are completely assembled
- b) Ensure sensors is powered on
- c) Check for all LED and Beeps expected from the sensors when powered on or connected to internet.
- d) Follow steps to connect sensors to internet and dashboard to check sensors activity



# 2. Pre-Deployment checks

- a) Sensors should be visible on the dashboard
- b) Ensure sensors is transmitting data
- c) To check the continuity of the data transmission

Name	PM <sub>2.5</sub> (µg/m <sup>3</sup> )	PM <sub>0.3</sub> Count	PM <sub>1</sub> (µg/m <sup>3</sup> )	PM <sub>10</sub> (µg/m <sup>3</sup> )	CO <sub>2</sub> (ppm)	Temp. (°C)	R. Hum. (%)	TVOC (Ind40)	NO <sub>x</sub> (Ind41)	Last Update	Admin
84fce606ede0_G4	2.6	380	1.7	4.1	403	27.7	85	—	—	18:53:01	⋮
84fce606f518	Offline	—	—	—	—	—	—	—	—	Apr 16, 17:00	⋮
84fce606f568	Offline	—	—	—	—	—	—	—	—	Apr 16, 18:10	⋮
84fce606f600_G3	5	444	1.5	5	406	27.5	88	—	—	18:50:11	⋮
84fce6070570	Offline	—	—	—	—	—	—	—	—	May 23, 17:23	⋮

# 3. Sensor deployment

- ❑ Avoid enclosed spaces and ensure adequate airflow (at least 270° circumference)
- ❑ Height Placement (at least 1.5 m)
- ❑ Do not place sensors near structures/objects that can affect air flow to the sensors or block the sensor intake (against a wall, near trees or on the ground blocking inlet)
- ❑ Do not place sensors near structures that can alter T or RH near the sensor (vents, exhausts, stacks)




# 3. Sensor deployment

- ❑ Do not place sensor in locations with risk of vibration, electrical shock or other potential hazards

## Additional components

- ❑ Local sim cards (GSM)
- ❑ >1.5 m Mounting Poles + Brackets (metallic/galvanized)
- ❑ Zip ties/fasteners
- ❑ USB Extension Cables



Micro SIM Card



# Important Metrics in Sensor Evaluation

- ❑ **Coefficient of Determination ( $R^2$ ):** Metric ranging from 0 to 1. The higher the value, the stronger the relationship and vice versa
- ❑ **Correlation:** It shows the linear relationship between sensor data and FEM T640 data
- ❑ **Mean Absolute Error (MAE):** The absolute difference between the sensors and the reference instruments. The larger MAE values, the higher measurement errors as compared to the reference instruments
- ❑ **Mean Bias Error (MBE):** The difference between the sensors and the reference instruments. MBE indicates the tendency of the sensors to underestimate (negative MBE values) or overestimate (positive MBE values)
- ❑ **Outliers :** Data points that significantly differ from other observations
- ❑ **Root Mean Square Error (RMSE):** A metric to calculate measurement errors and it is considered sensitive to outliers


# Data recovery

Cleansed data

$$\text{Data recovery (\%)} = \frac{N_{\text{valid data}}}{N_{\text{test period}}} * 100$$

six weeks - wet season

six weeks - dry season




NB: Sensor Data ≥ 75% data recovery is valid for evaluation


# Sensor Performance

- ☐ Intra-unit measurement variability
- ☐ Inter-unit measurement variability in PM levels when compared to the FEM T640

Wet Period






Dry Period



# Sensor Performance


- Determine relationship between sensors data and FEM T640 data
- Calculate measurement errors from sensors to compare with FEM T640




# Diurnal variation

- ❑ The tendency of the sensors to track the diurnal  $PM_{2.5}$  variations of the FEM T640 in both periods
- ❑ The tendency of the sensors to underestimate or overestimate  $PM_{2.5}$  concentration

**Wet Period**



**Dry Period**



# Sample Summary Statistics

	WET PERIOD (1-hour mean)				DRY PERIOD (1-hour mean)			
	$R^2$	MAE	MBE	RMSE	$R^2$	MAE	MBE	RMSE
Sensor_001	0.74	4.19	2.35	5.47	0.55	15.86	- 9.00	21.22
Sensor_002	0.71	3.87	0.21	5.27	0.56	16.27	-11.16	22.24
Sensor_003	0.74	4.28	2.46	5.53	0.60	15.42	-9.16	20.79


# Correction / Calibration of LCS under West Africa Meteorological Conditions

- ❑ Sensor readings are usually distorted by high relative humidity (RH), and seasonal dust events
- ❑ Without correction, data misrepresents true air quality, leading to unreliable health risk assessments and poor policy guidance.
- ❑ Develop correction model that incorporates LCS internal relative humidity and temperature data
- ❑ Statistical and machine learning models (e.g., MLR, Ridge, Random Forest, XGBoost, LGBM etc.)

# Seasonal correction

□ Our study showed notable variability between sensor readings and the FEM (top plots)

□ Different measurement accuracy and consistency across different types of LCS (bottom plots)




Nimo et al., (2025)

# Seasonal correction

## Three correction models

- Wet season: model data collected during the wet season
- Dry (non-Harmattan) season: Based on data collected during the dry season
- Dry (Harmattan) season: Based on data collected during the Harmattan season




	<b>Raw</b>	<b>Cal</b>
R <sup>2</sup> =	0.71	0.74
RMSE =	5.08	4.14
MAE =	3.72	2.89
nRMSE	30%	25%
MBE =	0.54	0.02

# Seasonal correction

## Three correction models

- Wet season: model data collected during the wet season
- Dry (non-Harmattan) season: Based on data collected during the dry season
- Dry (Harmattan) season: Based on data collected during the Harmattan season




	Raw	Cal
R <sup>2</sup>	0.80	0.92
RMSE=	8.3	4.68
MAE=	7.1	3.56
nRMSE=	20%	11%
MBE=	3.43	-0.52

# Seasonal correction

## Three correction models

- Wet season: model data collected during the wet season
- Dry (non-Harmattan) season: Based on data collected during the dry season
- Dry (Harmattan) season: Based on data collected during the Harmattan season



	Raw	Cal
$R^2 =$	0.63	0.74
RMSE=	27.5	13.7
MAE =	22.0	10.3
nRMSE=	40%	21%
MBE =	-20.7	-0.02

# The Afri-SET Approach

- ❑ To provide correction factors for individual LCS brand evaluated at Afri-SET
- ❑ All models created to calibrate low-cost sensors are available for download
- ❑ Reports are generated after each period (wet and dry)
- ❑ All reports, articles, publications and data are available at the Afri-SET website - [www.afrisets.org](http://www.afrisets.org)




# Acknowledgement



**Norsk institutt for luftforskning**  
**Norwegian Institute for Air Research**





# Thank you

[ahughes@ug.edu.gh](mailto:ahughes@ug.edu.gh)

Scan to <https://afrisets.org/>



Afri-Set West



Afri-Set West



info@afrisets.org



afrisets\_west



[www.afrisets.org](http://www.afrisets.org)



@AfriSET\_west